



PRODUCT PERFORMANCE REPORT

Document ID 1464703412

Issued on May 31st, 2016

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Auer**
 Company **Auer**
 Project reference **Auer**
 Project location **France**

PRODUCT IDENTIFICATION

Certification Diploma N° **14.01.001**
 Brand **AUER**
 Range **HRC70**
 Product reference **HRC70_11mono**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustics		
LwO	61.0	dB(A)
Air Conditioning		
Ph @ 7	8.1	kW
COP @ 7	3.3	
Dph Indoor	20.0	kPa
Ph @ 2	6.6	kW
Peh @ 2	2.44	kW
COP @ 2	2.7	
Dph Indoor @ 2	20.0	kPa
Class COP	A	
General		
MPS	230-1-50	
Refrigerant	R290	
Type of Water Regulation	FW/VO	
Heating Floor		
COP @ 7	3.9	
Dph Indoor	20.0	kPa
Ph @ 2	6.8	kW
Peh @ 2	2.06	kW
COP @ 2	3.3	
Dph Indoor @ 2	20.0	kPa
Class COP	B	
High Temperatures		
Ph @ 7	7.7	kW



PRODUCT PERFORMANCE REPORT

Document ID 1464703412

Issued on May 31st, 2016

FEATURE	VALUE	UNIT
COP @ 7	2.95	
Dph Indoor	10.0	kPa
Dph Indoor @ 2	10.0	kPa
Seasonal Efficiency for Heating - Average - Low T.		
Pdesignh Average W35	6.0	kW
SCOP Average W35	3.31	
η s Average W35	130.0	%
Very High Temperatures		
Ph @ 7	7.3	kW
Peh @ 7	3.04	kW
COP @ 7	2.4	
Dph Indoor	8.0	kPa
Ph @2	6.1	kW
Peh @ 2	2.98	kW
COP @ 2	2.05	
Dph Indoor @ 2	8.0	kPa